

LET YOUR DESIGNS

DEFINE YOUR VISION

# PRODUCT SPECIFICATION

## SKARB WALL PANELING SYSTEM CERTIFICATION



### AUTHORIZATION TO MARK

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report(s). This authorization also applies to the Multiple Listed model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The Certification Mark(s) may be applied only at the location of the Party Authorized to Apply Mark.

**Applicant:** Skarb Materials Inc.  
9 Humber St.  
Stratford, ON N5A 6S4  
Canada

**Party Authorized to Apply Mark:** See following page(s)  
**Evaluation Center:** Evaluation Services (ES)  
**Client Number:** 448551

Authorized By:   
Jean-Philippe Kayl, Director of Certification

Intertek Testing Services NA, Inc.  
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA  
Phone: 847-439-5667 Fax: 847-439-7320



Intertek

This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

<b>Testing Standard(s):</b>	CAN / ULC S102.2 (2018)
<b>Product:</b>	Skarb Materials Inc. - PVC Wall Panels

ATM for Spec Id: 83621

ATM Issue Date: 9/24/2025

**Listing Section(s):** BUILDING MATERIALS WITH SURFACE BURNING CHARACTERISTICS

**CSI Code(s):** 07 42 43 Composite Wall Panels

**Description:**

**Fluted Wall Panel:** This PVC panel consists of a ribbed pattern and measures 2900 mm in length, 160 mm in width, and 22 mm in thickness.

**Flat Wall Panel:** This laminated board is constructed with a foam core sandwiched between two PVC layers. The panel measures 2900 mm in length, 1220 mm in width, and 8 mm in thickness.


**Flame Spread Ratings**

Test Standard	Product(s)	Flame Spread	Smoke Development
CAN/ULC-S102.2	PVC Flat Wall Panel	70	350
	PVC Fluted Wall Panel	65	465

Showroom Address: 155 Frobisher Dr  
Suite 1-106, Waterloo, ON N2V 2E1

Warehouse Address: 9 Humber St,  
Stratford, ON N5A 6S4



 **1 (888) 75SKARB**

 [skarbmaterials.com](http://skarbmaterials.com)

 [info@skarbinc.com](mailto:info@skarbinc.com)

